Scope of Work for Property Located at: 3428-30 West Highland Blvd.														
	Property is: S	Single Family	y		Dup	lex		Other	4	4 Unit				
Date:	2/12/2013		_											
take no respon	ninimum requirements of the private lenders, institutions of the private lenders, institutions of the private lenders, institutions of the private lenders.	discovered afte	er the	inspe	ection (date,	or for c	missions	throug	gh error or ov	versight.			
Exterior C	Condition Repo	ort												
Location Site	Required Work Landscaping	τ	n/a	7	Yes		Note Self H	/Comm elp	ents				\$	Cost
	Steps/Handrails		n/a	7	Yes								\$	
	Service walks		n/a	7	Yes								\$	
	Fencing		n/a	V	Yes								\$	
	Parking		n/a	7	Yes								\$	
	Retaining walls		n/a	V	Yes								\$	
	Other		n/a		Yes								\$	
Garage	Other		n/a		Yes								\$	
	Singles: repair		n/a		Yes								\$	
	Shingles: Roof ove	r existing	n/a		Yes								\$	
	Shingles:Tear off &	re-roof	n/a		Yes								\$	
	Gutters/downspout	is	n/a		Yes								\$	
	Flashing		n/a		Yes								\$	
	Eaves		n/a		Yes								\$	
	Siding		n/a		Yes								\$	
	Doors		n/a		Yes								\$	
	Windows		n/a		Yes								\$	
	Slab		n/a		Yes								\$	
	Paint		n/a		Yes								\$	
	Electrical		n/a		Yes								\$	
	Other		n/a		Yes								\$	
Porches	Roof		n/a	V	Yes								\$	
	Deck-upper		n/a	7	Yes								\$	
	Decklower		n/a	V	Yes								\$	
	Steps/handrails		n/a		Yes	V							\$	750.00
	Ceiling		n/a	V	Yes								\$	
	Guardrails		n/a	V	Yes								\$	
	Structural		n/a	V	Yes								\$	
	Paint		n/a	V	Yes								\$	

n/a 🗌 Yes 🗹 Tuckpoint

\$

1,000.00

House

Chimney	n/a ☐ Yes ☑	\$ 500.00
Shingles: repair	n/a ☑ Yes 🗌	\$
Shingles: Roof over existing	n/a ☑ Yes 🗌	\$
Shingles:Tear off & re-roof	n/a ☐ Yes ☑	\$ 12,500.00
Gutters/downspouts	n/a ☑ Yes 🗌	\$
Flashing	n/a ☐ Yes ☑	\$ 1,250.00
Eaves	n/a ☐ Yes ☑	\$ 1,250.00
Siding	n/a ☐ Yes ☑	\$ 5,000.00
Storm Doors	n/a ☑ Yes □	\$
Prime ("main") Doors	n/a ☐ Yes ☑	\$ 1,850.00
Storm Windows	n/a ☑ Yes 🗌	\$
Prime ("main") Windows	n/a ☐ Yes ☑	\$ 15,000.00
Paint	n/a ☐ Yes ☑	\$ 5,000.00
Foundation	n/a ☐ Yes ☑ Tuckpoint	\$ 5,000.00
Electrical	n/a ☑ Yes 🗌	\$
Other	n/a 🗌 Yes 🗌	\$
Other	n/a 🗌 Yes 🗌	\$
Other	n/a 🗌 Yes 🗌	\$
Other	n/a 🗌 Yes 🗌	\$

Exterior: Estimated Cost:* \$ 49,100.00

^{*}average contracted cost. Actual costs may vary. Self help will reduce the amount.

interior Co	Unit: Entire unit (single family)				Lower unit of duplex	V		
	Upper unit of duplex Required Work				Other Lower Front			
Heating	Repair/replace boiler	n/a 🗀	Yes	7			\$	5,000.00
	Repair radiation	n/a 🗀	Yes	7			\$	2,000.00
	Repair/replace furnace	n/a ✓	Yes				\$	
	Repair ductwork	n/a ✓	Yes				\$	
	Replace thermostat	n/a ✓	Yes				\$	
	Repair/replace grilles	n/a [✓	Yes				\$	
Electrical	Tune boiler/furn. insp ht exchang	en/a √	Yes				\$	
	Repair/replace receptacles	n/a	Yes	1			\$	100.00
	Repair/replace switches	n/a	Yes	1			\$	100.00
	Repair/replace fixtures	n/a 🗌	Yes	4			\$	100.00
	Install outlets and circuits	n/a [Yes	1			\$	1,000.00
	Install outlets and circuits	n/a ✓	Yes				\$	
	Install outlets and circuits	n/a ✓	Yes				\$	
	Install outlets and circuits	n/a ✓	Yes				\$	
	Upgrade service	n/a	Yes	1			\$	2,000.00
	Other	n/a	Yes				\$	
	Other	n/a	Yes				\$	
Plumbing	Repair/replace kitchen sink	n/a _	Yes				\$	
	Repair/replace kitchen sink fauce	et n/a	Yes				\$	
	Repair/replace tub	n/a	Yes				\$	
	Repair/replace tub faucet	n/a	Yes				\$	
	Repair/replace toilet	n/a	Yes				 \$	
	Repair/replace lavatory	n/a	Yes				\$	
	Repair/replace lavatory faucet	n/a	Yes				 \$	
	Repair/replace wash tub	n/a	Yes				 \$	
	Repair/replace wash tub faucet	n/a	Yes				\$	
	Unclog piping:	n/a	Yes	7			 \$	
	Repair drain/waste/vent piping	n/a 🗀	Yes	V			\$	750.00
	Repair water piping	n/a 🗀	Yes	√			\$	750.00
	Repair/replace water heater	n/a 🗀	Yes	V			\$	800.00
	Other	n/a 🗀	Yes	4	Complet Kitchen		\$	1,750.00

\$

2,250.00

Windows								
	Replace broken glass	n/a	4	Yes [\$	
	Repair or replace sash	n/a	7	Yes [\$	
Doors								
	Repair or replace doors	n/a		Yes [√		\$	600.00
	Repair or repl. locks/latches	n/a		Yes [4	Self Help	\$	250.00
Walls/Ceiling	Repair or repl. @ defective	n/a		Yes [√		\$	750.00
Paint	Repair or repl. @ defective	n/a		Vac. 5	_		r.	1,500.00
	Repair or repr. @ defective	n/a	Ш_	Yes [<u> </u>		\$	1,500.00
Fire Safety	Install smoke/CO alarm:bsmt.	n/a		Yes [√	Self Help	\$	50.00
	Install smoke/CO alarm: 1st flr.	n/a		Yes [7	Self Help	\$	50.00
	Install smoke/CO alarm: 2nd flr.	n/a		Yes [√	Self Help	\$	50.00
Handrails	Repair/replace defective	n/a	[7]	Yes [7	Self Help	\$	
Stairs						-		
Floors	Repair defective	n/a	√	Yes			\$	
	Repair defective	n/a		Yes [√		\$	1,150.00
Other		n/a		Yes [\$	
		n/a		Yes [\$	
	_	n/a		Yes [\$	
	_	n/a		Yes [\$	

Interior Co	ondition Report								
	Unit: Entire unit (single family) Upper unit of duplex					Lower unit of duplex Other	<u>_</u>		
Mechanical Heating	Required Work					Lower Rear			
	Repair/replace boiler	n/a		Yes	√			 	\$ 5,000.00
	Repair radiation	n/a		Yes	V				\$ 2,000.00
	Repair/replace furnace	n/a	4	Yes					\$
	Repair ductwork	n/a	4	Yes					\$
	Replace thermostat	n/a	7	Yes					\$
	Repair/replace grilles	n/a	V	Yes					\$
Electrical	Tune boiler/furn. insp ht exchang	e n/a	V	Yes					\$
Licoti ioui	Repair/replace receptacles	n/a		Yes	4				\$ 100.00
	Repair/replace switches	n/a		Yes	V			 	\$ 100.00
	Repair/replace fixtures	n/a		Yes	4				\$ 100.00
	Install outlets and circuits	n/a		Yes	√				\$ 1,000.00
	Install outlets and circuits	n/a	V	Yes					\$
	Install outlets and circuits	n/a	4	Yes					\$
	Install outlets and circuits	n/a	4	Yes					\$
	Upgrade service	n/a		Yes	√				\$ 2,000.00
	Other	n/a		Yes					\$
Disambina	Other	n/a		Yes					\$
Plumbing	Repair/replace kitchen sink	n/a		Yes					\$
	Repair/replace kitchen sink fauce	et n/a		Yes					\$
	Repair/replace tub	n/a		Yes					\$
	Repair/replace tub faucet	n/a		Yes					\$
	Repair/replace toilet	n/a		Yes					\$
	Repair/replace lavatory	n/a		Yes					\$
	Repair/replace lavatory faucet	n/a		Yes					\$
	Repair/replace wash tub	n/a		Yes					\$
	Repair/replace wash tub faucet	n/a		Yes					\$
	Unclog piping:	n/a		Yes	7				\$
	Repair drain/waste/vent piping	n/a		Yes	V				\$ 750.00
	Repair water piping	n/a		Yes	√				\$ 750.00
	Repair/replace water heater	n/a		Yes	4				\$ 800.00
	Other	n/a		Yes	4	Complet Kitchen			\$ 1,750.00

2,250.00

Windows								
	Replace broken glass	n/a [V	Yes [\$	
	Repair or replace sash	n/a [7	Yes [\$	
Doors			_		_		•	
	Repair or replace doors	n/a [Yes 🗸	✓		\$	600.00
	Repair or repl. locks/latches	n/a		Yes 🗔	√ S	Self Help	\$	250.00
Walls/Ceiling	s Repair or repl. @ defective	n/a [Yes 🖸	√		\$	1,750.00
Paint	Repair or repl. @ defective	n/a [П	Yes 🔽	7 1		\$	1,850.00
Fina Cafatu			<u> </u>				· ·	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
Fire Safety	Install smoke/CO alarm:bsmt.	n/a [Yes 🖸	√ S	Self Help	\$	50.00
	Install smoke/CO alarm: 1st flr.	n/a [Yes 🖸	√ S	Self Help	\$	50.00
	Install smoke/CO alarm: 2nd flr.	n/a		Yes 🖸	√ 5	Self Help	\$	50.00
Handrails	Repair/replace defective	n/a [[J]	Yes [¬ .s	Self Help	\$	
Stairs				_		•	·	
Floors	Repair defective	n/a [V	Yes [\$	
	Repair defective	n/a [Yes 🔽	7		\$	1,250.00
Other		n/a [Yes [\$	
		n/a [Yes [\$	
		n/a [Yes [\$	
		n/a [Yes [\$	

Interior Co	ondition Report					
	Unit: Entire unit (single family) Upper unit of duplex			Lower unit of duplex Other		
Mechanical Heating	Required Work			<u>Upper Rear</u>		
lieating	Repair/replace boiler	n/a 🔲	Yes 🗸		\$	5,000.00
	Repair radiation	n/a 🔲	Yes 🗸		\$	2,000.00
	Repair/replace furnace	n/a ✓	Yes 🗌		\$	
	Repair ductwork	n/a ✓	Yes 🗌		\$	
	Replace thermostat	n/a ✓	Yes 🗌		\$	
	Repair/replace grilles	n/a ✓	Yes 🗌		\$	
Electrical	Tune boiler/furn. insp ht exchang	jen/a ☑	Yes 🗌		\$	
Liectricai	Repair/replace receptacles	n/a 🗌	Yes ✓		\$	100.00
	Repair/replace switches	n/a 🗌	Yes ✓		\$	100.00
	Repair/replace fixtures	n/a 🗌	Yes ✓		\$	100.00
	Install outlets and circuits	n/a 🗌	Yes ✓		\$	1,000.00
	Install outlets and circuits	n/a ✓	Yes 🗌		\$	
	Install outlets and circuits	n/a ✓	Yes 🗌		\$	
	Install outlets and circuits	n/a ✓	Yes 🗌		\$	
	Upgrade service	n/a 🗌	Yes ✓		\$	2,000.00
	Other	n/a 🗌	Yes 🗌		\$	
	Other	n/a 🗌	Yes 🗌		\$	
Plumbing	Repair/replace kitchen sink	n/a 🔲	Yes 🗌		\$	
	Repair/replace kitchen sink fauce	et n/a	Yes 🗌		\$	
	Repair/replace tub	n/a 🗌	Yes 🗌		\$	
	Repair/replace tub faucet	n/a 🗌	Yes 🗌		\$	
	Repair/replace toilet	n/a 🗌	Yes 🗌		\$	
	Repair/replace lavatory	n/a 🗌	Yes 🗌		\$	
	Repair/replace lavatory faucet	n/a 🗌	Yes 🗌		\$	
	Repair/replace wash tub	n/a 🗌	Yes 🗌		\$	
	Repair/replace wash tub faucet	n/a 🗌	Yes 🗌		\$	
	Unclog piping:	n/a 🗌	Yes 🗸		\$	
	Repair drain/waste/vent piping	n/a 🗌	Yes 🗸		\$	750.00
	Repair water piping	n/a 🗌	Yes 🗸		\$	750.00
	Repair/replace water heater	n/a 🗌	Yes 🗸		\$	800.00
	Other	n/a □	Yes 🗸	Complet Kitchen	\$	1,750.00

Other

2,250.00

\$

Windows							
	Replace broken glass	n/a	✓ ,	Yes 🗌		\$	
	Repair or replace sash	n/a	√ ,	Yes 🗌		\$	
Doors		, ,		. –		•	
	Repair or replace doors	n/a		Yes ✓		\$	600.00
	Repair or repl. locks/latches	n/a []	Yes 🗸	Self Help	\$	250.00
Walls/Ceiling	Repair or repl. @ defective	n/a [Yes 🗸		\$	2,250.00
Paint	Repair or repl. @ defective	n/a [¬ ,	Yes ☑		\$	1,750.00
Fine Onforce						·	
Fire Safety	Install smoke/CO alarm:bsmt.	n/a		Yes 🗸	Self Help	\$	50.00
	Install smoke/CO alarm: 1st flr.	n/a		Yes 🗸	Self Help	\$	50.00
	Install smoke/CO alarm: 2nd flr.	n/a [_ ,	Yes ☑	Self Help	\$	50.00
Handrails	Repair/replace defective	n/a [ন ন	Yes □	Self Help	\$	
Stairs					•	·	
Floors	Repair defective	n/a [<u> </u>	Yes		\$	
	Repair defective	n/a [Yes 🗸		\$	400.00
Other		n/a [Yes 🗌		\$	
		n/a		Yes 🗌		\$	
		n/a		Yes 🗌		\$	
		n/a		Yes 🗌		\$	

Interior Co	ondition Report							
	Unit: Entire unit (single family) Upper unit of duplex	□			Lower unit of duplex Other			
Mechanical Heating	Required Work				Upper Front			
rieating	Repair/replace boiler	n/a [<u> </u>	∕es []		\$	5,000.00
	Repair radiation	n/a [] \	∕es []		\$	2,000.00
	Repair/replace furnace	n/a 🗔	/ Y	es []		\$	
	Repair ductwork	n/a 🗔	/ Y	es []		\$	
	Replace thermostat	n/a 🗔	/ Y	es []		\$	
	Repair/replace grilles	n/a 🔄	/ /	es []		\$	
Flootsiaal	Tune boiler/furn. insp ht exchang	en/a 🛭	/ Y	es []		\$	
Electrical	Repair/replace receptacles	n/a [_ \	∕es [-]		\$	100.00
	Repair/replace switches	n/a [<u> </u>	∕es []		\$	100.00
	Repair/replace fixtures	n/a	<u> </u>	∕es [-]		\$	100.00
	Install outlets and circuits	n/a	<u> </u>	∕es [-]		\$	1,000.00
	Install outlets and circuits	n/a	/ Y	es []		\$	
	Install outlets and circuits	n/a	/ Y	es []		\$	
	Install outlets and circuits	n/a	/ Y	es []		\$	
	Upgrade service	n/a	_ \	∕es [-]		\$	2,000.00
	Other	n/a [<u> </u>	es []		\$	
	Other	n/a [<u> </u>	es []		\$	
Plumbing	Repair/replace kitchen sink	n/a [<u> </u>	es []		\$	
	Repair/replace kitchen sink fauce	et n/a	<u> </u>	es []		\$	
	Repair/replace tub	n/a	<u> </u>	es []		\$	
	Repair/replace tub faucet	n/a [<u> </u>	es []		\$	
	Repair/replace toilet	n/a [<u> </u>	es []		\$	
	Repair/replace lavatory	n/a [<u> </u>	es []		\$	
	Repair/replace lavatory faucet	n/a [<u> </u>	es []		\$	
	Repair/replace wash tub	n/a [] \	es []		\$	
	Repair/replace wash tub faucet	n/a [] \	es []		\$	
	Unclog piping:	n/a [] \	∕es 🖸]		\$	
	Repair drain/waste/vent piping	n/a	<u> </u>	∕es []		\$	750.00
	Repair water piping	n/a	<u> </u>	∕es []		\$	750.00
	Repair/replace water heater	n/a	<u> </u>	∕es [-]		\$	800.00
	Other	n/a	_ \	∕es [-	Complet Kitchen		\$	1,750.00

\$

2,250.00

Windows								
	Replace broken glass	n/a	√	Yes			\$	
	Repair or replace sash	n/a	V	Yes			\$	
Doors	Repair or replace doors	n/a		Yes	7		\$	600.00
	Repair or repl. locks/latches	n/a		Yes	4	Self Help	\$	250.00
Walls/Ceiling	gs							
	Repair or repl. @ defective	n/a		Yes	✓		\$	2,250.00
Paint	Repair or repl. @ defective	n/a		Yes	7		\$	2,250.00
Fire Safety								
•	Install smoke/CO alarm:bsmt.	n/a		Yes	V	Self Help	\$	50.00
	Install smoke/CO alarm: 1st flr.	n/a		Yes	7	Self Help	\$	50.00
	Install smoke/CO alarm: 2nd flr.	n/a		Yes	V	Self Help	\$	50.00
Handrails	Repair/replace defective	n/a	7	Yes		Self Help	\$	
Stairs								
Floors	Repair defective	n/a	√	Yes	Ш		\$	
1 10015	Repair defective	n/a	П	Yes	v		\$	400.00
Other	-							
		n/a		Yes			\$	
		n/a		Yes			\$	
		n/a		Yes			\$	
		n/a		Yes			\$	
						Interior: Estimated Cost:	\$	87,950.00
						Total Exterior and Interior Cost:*	\$	137,050.00
						*average contracted cost. Actual costs may vary. Self help will reduce t	he amount.	

Inspected by: Jason R Golec Date: 2/15/13

Self Help

Work listed as "self help" means the cost estimate includes only the cost of the materials, not labor or equipment.

Important Information Regarding Permits

All plumbing, heating, electrical, and structural repairs require permits before work can start. Permits are also required for other work such as new siding, new drywall, new doors. Permits are obtained at the Development Center located on the first floor of 809 N. Broadway.

Licensed contractors must do the above work, although owner occupants may be eligible to do maintenance work and structural/carpentry repairs.

Owner occupants may be eligible to do plumbing work on the unit they live in, but check with the plumbing inspector first.

Generally, minor carpentry repairs, plaster patching, and painting do not require permits.

Anyone disturbing painted surfaces must assume they contain lead paint if the home was built before 1978. Contractors must be licensed to do lead abatement and must obtain a permit. Permits are obtained from the Health Department, located on the first floor of 841 N. Broadway.